

CERTIFICATE OF COMPLIANCE

Certificate Number E514085
Report Reference E514085-20200603
Issue Date 2024-FEBRUARY-20

Issued to: RED SKY LIGHTING LLC
9370 Pittsburgh Ave, RANCHO CUCAMONGA, CA 91730-5557

**This certificate confirms that
representative samples of**

EMERGENCY LIGHTING AND POWER EQUIPMENT FOR
USE IN HAZARDOUS LOCATIONS
See Addendum page for Models

Have been evaluated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 844 - Luminaires for Use in Hazardous (Classified)
Locations;
UL 924 - Emergency Lighting and Power Equipment.

Additional Information: See UL Product iQ® at <https://iq.ulprospector.com> for
additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Conformity Assessment Director

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E514085
Report Reference E514085-20200603
Issue Date 2024-FEBRUARY-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Products Covered	Product Designation
Class I, Division 1, Groups C and D	LNT-80 Followed by 120-277; followed by -60, -T2 or -110; followed by H1; followed by -CG or -FG; followed by -PEND or -YOKE; followed by -GREY, -BLACK, -WHITE or -BRONZE; followed by -EM
Class I, Division 2, Groups A, B, C and D; Class II, Division 1, Groups E, F and G	LNR Followed by -40, -80, followed by -120-277, followed by -3000K, -4000K, -5000K or -5700K, followed by 110, followed by H2, followed by -CLR or -DIFF, followed by -PEND or -YOKE, STAN, CHAIN, RING, followed by -GRY, -BLK, -WTE or -BRZ, followed by -EM.
Class I, Division 1, Groups C and D	LNT; Followed by -80; Followed by -120-277; Followed by -3K, -4K, -5K; Followed by -110, -60 or -T2; Followed by -H1; Followed by -CG or -DG; Followed by -GRY, -BLK, -WHT or -BRZ; Followed by -PND or -YKE; Followed by -EM 1 – Fixture Series LNT - For all luminaires 2 – Wattage 80 - 80W 3 – Voltage 120-277 - 120-277V AC 4 – Color Temperature 3K - 3000K 4K - 4000K 5K - 5000K 5 – Beam Angle 110 - 110° 60 - 60° T2 - Type II

B. Mahrenholz

Bruce Mahrenholz, Conformity Assessment Director

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E514085
Report Reference E514085-20200603
Issue Date 2024-FEBRUARY-20

	<ul style="list-style-type: none">6 – Hazloc Rating H1 - C1D17 – Lens CG - Clear Glass DG - Diffuse Glass8 – Finish Color GRY - Grey BLK - Black WHT - White BRZ - Bronze9 – Mounting PND - Pendant YKE - Yoke10 – Battery EM – 90 mins
Class I, Division 2, Groups A, B, C and D; Class II, Division 1, Groups E, F and G	<p>LNR; Followed by -40, or -80; Followed by -120-277; Followed by -3K, -4K, -5K; Followed by -H2; Followed by -CP or -DP; Followed by -GRY, -BLK, -WHT or -BRZ; Followed by -PND or -YKE; Followed by -EM.</p> <ul style="list-style-type: none">1 – Fixture Series LNR - For all luminaries2 – Wattage 40 - 40W 80 - 80W3 – Voltage 120-277 - 120-277V AC4 – Color Temperature 3K - 3000K 4K - 4000K 5K - 5000K 57K - 5700K5 – Hazloc Rating H2 - C1D2 / C2D1 / C36 – Lens CP - Clear PC DP - Diffuse PC7 – Finish Color GRY - Grey BLK - Black WHT - White BRZ - Bronze

B. Mahrenholz

Bruce Mahrenholz, Conformity Assessment Director

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E514085
Report Reference E514085-20200603
Issue Date 2024-FEBRUARY-20

	8 – Mounting PND - Pendant YKE - Yoke 9 – Battery EM – 90 mins
--	--

B. Mahlenz

Bruce Mahrenholz, Conformity Assessment Director

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>

